




Notification Provided By:  
Cool Roof Rating Council  
449 15th St. Suite 400  
Oakland, CA 94612

# NOTIFICATION OF PRODUCT RATING


**Product Brand:** CeDUR  
**Product Model:** Golden Cedar  
**Company:** CeDUR  
**Contact Name:** Paul Malloreay  
**Telephone:** 720-974-9200  
**Website:** <http://www.cedur.com>  
**Product Type:** Steep Slope: Polymer/Composite Steep-Slope Products  
**Initial SRI:** 21  
**3 Year SRI** Pending  
**Slope Types:** Steep  
**Color:** Tan, Brown

Notification Provided To:  
**CeDUR**  
3590 Himalaya Rd.  
Aurora, CO 80011

		Initial	Weathered
	<b>Solar Reflectance</b>	<b>0.23</b>	<b>Pending</b>
	<b>Thermal Emittance</b>	<b>0.87</b>	<b>Pending</b>
	Rated Product ID	1292-0001	
	Licensed Manufacturer	1292	
	Classification	Production Line	
Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.			
Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.			

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

This certificate is valid until an updated certificate is issued that includes product aged data.

  
\_\_\_\_\_  
Technical Reviewer

  
\_\_\_\_\_  
Application Reviewer

  
\_\_\_\_\_  
Management Approval

5/19/2017  
\_\_\_\_\_  
Date

